

10



## **AUGLAIZE COUNTY**

### ***Engineering Department***

P.O. Box 59  
1014 S. Blackhoof Street  
Wapakoneta, Ohio 45895

TELEPHONE 419-739-6520  
FAX 419-739-6521  
Email: [augcoeng@augcoeng.com](mailto:augcoeng@augcoeng.com)



*Douglas Reinhart*  
COUNTY ENGINEER

**Mike and Chris Kinstle  
12221 Canning Factory Road  
Wapakoneta, Ohio 45895**

**August 1, 2006**

#### **In re: Flood Plain Certification**

**The proposed building site is 1000' east of the SW corner of Section 31 S, Duchouquet Township, Auglaize County and approximately 300' north of Canning Factor Road.**

**Attached is FEMA flood plain map # 39011C0105 C where I have located said parcel. Based upon bridge and flood data along Canning Factory Road and SR# 33, the 100 year flood elevation along Pusheta Creek, along the north edge of this parcel is 882.0.**

**Utilizing past flood plain certification data, USGS maps and a site inspection I have determined the following:**

- (1) The extreme northern 30' of the 5.238 acre parcel is the ditch bank of Pusheta Creek and is within the 100 year flood plain.**
- (2) There also exists a waterway approximately 30' in width along the most western portion of the parcel that would also be subject to the 100-year flood.**
- (3) Total area of this parcel within the 100 year flood plain is less than one-third of an acre.**
- (4) The balance of the 5.238 acre parcel is elevated and well above the 100 year flood plain and is located in Zone X of the FEMA maps.**

**Douglas Reinhart, P.E., P.S.  
Auglaize County Engineer  
Auglaize County Flood Plain Coordinator**