

AUGLAIZE COUNTY

Engineering Department
P.O. Box 59
1014 S. Blackhoof Street

1014 S. Blackhoof Street Wapakoneta, Ohio 45895

TELEHONE 419-739-6520 FAX 419-739-6521 Email: doug@augcoeng.com



Douglas Reinhart
COUNTY ENGINEER

Curt Anderson RS, EHD Auglaize County Health Department

February 19, 2020

In re: Flood Plain elevation @ 16412 Hengstler Road

The 100-year flood plain elevation (1988 datum) for the above site adjacent to the Auglaize River is 898.0. The proposed leach field for that parcel, as per attached drawing, is outside the flood plain.

Douglas Reinhart, P.E., P.S. Auglaize County Engineer

Cc: Tom Doorley, Zoning Inspector
Duchouquet Township



February 12, 2020

Mr. Tom Doorley 17455 Hengstler Road Wapakoneta, Ohio 45895

Dear Mr. Doorley:

The Auglaize County Engineers office indicated that the zoning officers for each township are responsible for determining the flood plain elevation of parcels within their townships. I have a potential building lot located at 16412 Hengstler Road that is on a small rise that is surrounded by what appears to be a flood prone area. I have included the site and septic plan with surface elevations for your review.

I just wanted to make sure that the septic system will be out of the 100 year flood plain.


Thanks,

Curt Anderson RS, EHD

Auglaize County Health Department

813 Defiance St.

Wapakoneta, Ohio 45895



SYSTEM INVE (BOTTOM OF F	
HOUSE OUTLET	900.27
SEPTIC TANK (INLET)	900.01
SEPTIC TANK (OUTLET)	899.84
DIST. BOX (INLET)	899.27
DIST. BOX (OUTLET)	899.10
FIRST LEACH LINE	899.04
SECOND LEACH LINE	898.65
THIRD LEACH LINE	898.20
FOURTH LEACH LINE	897.67
	

FLAG LEGEND

- = ORANGE STAKE
- WHITE FLAG
- w = GREEN FLAG

 $_{9}$ $^{\chi}$ = EX. SPOT ELEVATION



SCALE 1" = 30'

NEW SEPTIC SYSTEM PLAN FOR:

Bret & Melanie Marquis 16412 Hengstler Rd., Wapakoneta Auglaize County, Ohio

DATE 1/13/20 REVISIONS 1/16/20



6807 Catamaran Drive, Huntsville, Ohio 43324 (937) 539-8820 cjengineering@embarqmail.com

