



## AUGLAIZE COUNTY

### Engineering Department

P.O. Box 59  
1014 S. Blackhoof Street  
Wapakoneta, Ohio 45895

TELEPHONE 419-739-6520  
FAX 419-739-6521  
Email: [augcoeng@augcoeng.com](mailto:augcoeng@augcoeng.com)



*Douglas Reinhart*  
COUNTY ENGINEER

**Thomas Doorley**  
**Duchouquet Township Zoning Inspector**  
**March 3, 2004**

**Dear Tom;**

**Enclosed is a survey plat from Kent Surveying showing the proposed construction for the Holtzapple property on SR# 67, in Section 22, Duchouquet Township.**

**Flood Plain elevation = 892.3**  
**Ground at site of construction = 896.0**  
**Proposed first floor elevation = 901.4**

**This plat clearly shows the location of the construction to be out of the designated FEMA flood plain.**

**Douglas Reinhart, P.E., P.S.**  
**Auglaize County Engineer**  
**Auglaize County Flood Plain Coordinator**