



AUGLAIZE COUNTY

Engineering Department

P.O. Box 59
1014 S. Blackhoof Street
Wapakoneta, Ohio 45895

TELEPHONE 419-739-6520
FAX 419-739-6521
Email: doug@augcoeng.com



Douglas Reinhart
COUNTY ENGINEER

FEMA Flood Elevation Certification

Section 3, German Township, Auglaize County, Ohio

500' +/- north of Lock Two Road, West of Western Ohio Rail Authority Property

March 23, 2015

The BFE for the site of the proposed cell tower is 926.9 (NAVD 88) or 927.50 (NAVD29). The topographic map provided shows the pad elevation for the tower and supports to be 928 with the 928 contour lines being also within the site. Therefore, this proposed improvement is not within the FEMA Flood Plain and is not subject to flood plain regulations.

The FEMA maps for this county were generated in 1989 with the use of 5' contour lines and in many cases, found to be quite inaccurate. Your field survey clearly shows this site as being outside of Zone "A" and in Zone "X".

Douglas Reinhart, P.E., P.S.
Auglaize County Engineer
Auglaize County Flood Plain Coordinator