
**AUGLAIZE COUNTY****Engineering Department**

P.O. Box 59
1014 SOUTH BLACKHOOF STREET
WAPAKONETA, OHIO 45895
TELEPHONE (419) 738-3219 738-2713
FAX (419) 738-5426
email: augcoeng@bright.net



Douglas Reinhart
COUNTY ENGINEER

Walnut Grove Church
Section 14, Noble Township
Auglaize County

November 22, 2000

In re: Request to "fill" around Church property

I see no problem with the proposed minor filling of the ½ acre tract of ground surrounding the existing parcel owned by the Walnut Grove Church. The control for the flood elevation in the area of the church is the Schillinger road bridge and roadway elevation. The proposed fill will not effect those structures capacities.

Douglas Reinhart, P.E., P.S.
Auglaize County Sanitary Engineer
Auglaize County Flood Plain Coordinator