



AUGLAIZE COUNTY

Engineering Department

P.O. Box 59
1014 SOUTH BLACKHOOF STREET
WAPAKONETA, OHIO 45895
TELEPHONE (419) 738-3219 738-2713
FAX (419) 738-5426



Douglas Reinhart
COUNTY ENGINEER

Feb. 21, 1997

Don Miller
Midwest Guardian, Inc.
~~100 Keller Dr.~~ 727 KELLER DR.
Wapakoneta, Ohio 45895

In response to your request as to whether or not your structure is in a flood plain, please see the attached information.

According to the Flood Insurance Rate Map from FEMA, your structure is located in Zone X. Therefore it is not in a flood plain.

The U.S.G.S. Elevation of the ground level at your building is 885' above mean sea level. The 100 year flood elevation for that location is 884'. Although portions of your property may be inundated by a 100 year flood, your building would not.

Additional information for your records:

The Latitude and Longitude for the building is: Latitude 40°-34'-40"
Longitude: 84°-10'-50"

If you have any questions or need additional information please give me a call.

Sincerely,

Larry McLean
Larry McLean